

1 Q. **References: Volume I, 2019 - 2023 Capital Plan, page 5 lines 18 to 21.**

2 *“Hydro has developed an updated maintenance plan for the*
 3 *penstocks on its major generators, with scheduled PM9 (6-year*
 4 *frequency – comprehensive internal inspection), PM6 (annual*
 5 *frequency – external inspection), and PM4 (monthly frequency –*
 6 *external inspection) inspections.”*

7

8 Please provide a list of hydroelectric generating stations with major generators, and
 9 a list of hydroelectric generating stations not considered to have major generators.

10

11 A. Table 1 lists the hydroelectric generating stations that contain major units.

Table 1: Generating Stations with Major Generating Units

Plant Name	No. Generating Units
Bay d’Espoir Powerhouse 1	6
Bay d’Espoir Powerhouse 2	1
Upper Salmon	1
Granite Canal	1
Star Lake	1
Cat Arm	2
Hind’s Lake	1
Paradise River	1

12 Table 2 lists the hydroelectric generating stations that do not contain major units.

Table 2: Generating Stations without Major Generating Units

Plant Name	No. Generating Units
Snook’s Arm	1
Venam’s Bight	1
Roddickton	1