

1 Q. Please provide the proposed decommissioning schedule for the four current diesel systems: (a)
2 Charlottetown and Pinsent's Arm, (b) Mary's Harbour and Lodge Bay, (c) Port Hope Simpson,
3 and (d) St. Lewis based on immediate interconnection of all six communities with a single
4 regional diesel generating station in Port Hope Simpson.

5

6

7 A. The decommissioning schedule for each plant will be developed in detail during the execution
8 phase of this project, if approved. Generally, the decommissioning of each plant would
9 commence once power is being supplied from the fully tested and commissioned regional plant.
10 The order of decommissioning or duration of the work would depend on numerous factors
11 including the time of year, complexity of decommissioning scope, and available contractors to
12 complete the work at each site.