

1 Q. **Reference: 2021 Capital Budget Supplemental Application Approval of the Construction of**  
2 **Hydro’s Long-term Supply Plan for Southern Labrador – Revision 1 – Safe and Reliable Power**  
3 **Supply to Charlottetown – Reply, Attachment 1, Southern Labrador Communities - Integrated**  
4 **Resource Plan Response to Newfoundland and Labrador Board of Commissioners of Public**  
5 **Utilities Information Request Issues Aug 1, 2023, page 33 of 74, Table 14.**

6 Please confirm whether the items associated with PHS Plant Upgrade, MSH Plant Upgrade and  
7 SLE Plant Upgrade include the cost of upgrades to the plant auxiliary systems including the main  
8 bus, service conductors and substation transformers.

9

10

11 A. *This response has been provided by Midgard Consulting Inc.*

12 The PHS<sup>1</sup> Plant Upgrade, MSH<sup>2</sup> Plant Upgrade and the SLE<sup>3</sup> Plant Upgrade costs include the  
13 known systems required to operate these diesel generating stations in an interconnected  
14 manner, including upgrades to the main bus, service conductors, and substation transformers.

---

<sup>1</sup> Port Hope Simpson (“PHS”).

<sup>2</sup> Mary’s Harbour (“MSH”).

<sup>3</sup> St. Lewis (“SLE”).