| 1 | Q. | Reference: Schedule 1 – Long-Term Supply for Southern Labrador – Phase 1 |
|----|----|--|
| | | |
| 2 | | Page 4, line 2, states "The Port Hope Simpson Diesel Generating Station has three units with an |
| 3 | | installed capacity of 1,725 kW" What is the plan for the three units once the new regional |
| 4 | | diesel generating station is completed in Port Hope Simpson? |
| | | |
| 5 | | |
| - | | |
| 6 | | |
| 7 | A. | Newfoundland and Hydro plans to reuse all three units currently in service in Port Hope |
| 0 | | |
| 8 | | Simpson. Units 2099 and 2100 are expected to be utilized in the Makkovik Diesel Generating |
| 9 | | Station, which has two units ¹ expected to reach end-of-life in the 2024–2026 timeframe. Unit |
| 10 | | 2073 will likely be installed in the St. Lewis Diesel Generating Station, which has a unit ² of the |
| 11 | | same size projected for replacement in 2026. |

¹ Units 2029 and 3033. ² Unit 2080.