

1 Q. **Reference: Project - Upgrade Waste Water Equalization System - Holyrood**

2 Hydro has advised that the waste water equalization system will still be needed "post-steam".
3 Will there be any change in how the system is utilized post-steam and if so, please identify and
4 explain all those changes

5

6

7 A. There will be no change in how the system is utilized post steam. The volume of effluent being
8 treated through the equalization system is expected to decrease; however, both basins are
9 required to remain in service. Periodic effluent will still require separate treatment through the
10 waste water treatment plant and continuous effluent will still require treatment through
11 retention.