

1 Q. **Project - Upgrade Waste Water Equalization System - Holyrood**

2 With reference to IC-NLH-007, if the Bio-aerosol Assessment recommendation were to be  
3 followed, could the mechanical systems issues also raised as a justification for this project be  
4 addressed without wholesale replacement of the building? If yes, then has Hydro assessed the  
5 cost of addressing the mechanical systems issues in such a manner?

6

7

8 A. The mechanical issues, raised as a justification for the project, could be addressed without  
9 wholesale replacement of the building. The replacement of the mechanical systems alone will  
10 not, however, adequately address the many other issues with the existing facility. As outlined in  
11 Hydro's response IC-NLH-006 of this proceeding, keeping the existing building was not  
12 considered a viable option.