

1 Q. **Reference: Tab 15; Volume II: Overhaul Diesel Units – Various (2021)**

2 Does the proposed 1.8 MW Nain Wind Micro Grid Project affect the timing (or need altogether)
3 for the proposed diesel engine overhauls of Nain’s Unit 2085 and Unit 591 currently scheduled
4 for 2022 and 2023 respectively? If so, please provide the new scheduled overhaul dates. If not,
5 please explain.

6

7

8 A. The Nain Wind Micro Grid project is not expected to have an impact on the proposed diesel
9 engine overhaul of Nain’s Unit 2085 currently scheduled for 2022. The Nain Wind Micro Grid
10 project is still in the front-end engineering and design phase and operational impacts have yet to
11 be assessed. If the Nain Wind Micro Grid project advances to execution, it is not expected to be
12 in service until 2022. Given that Unit 2085 is scheduled to be overhauled in the same year, there
13 would not be an appreciable impact on operating hours which would support a change to the
14 overhaul schedule.

15 Newfoundland and Labrador Hydro (“Hydro”) has yet to determine if the proposed Nain Wind
16 Micro Grid project would impact the diesel engine overhaul of Unit 591 scheduled for 2023.
17 Hydro will continue to monitor the incurred operating hours on Unit 591 and will evaluate the
18 potential impact the Nain Wind Micro Grid project has on the diesel engine replacement
19 schedule.