| 1 | Q. | Reference: Application, Purchase Meters and Metering Equipment (2023) |
|---|----|---|
| 2 | | Are these meters compatible with time-of-use rates? |
| 3 | | |
| 4 | | |
| 5 | Α. | The meters proposed for purchase in Newfoundland and Labrador Hydro's 2023 Capital Budget |
| 6 | | Application are industrial/wholesale meters and can be programmed with time-of-use rates. |