

1 Q. **Reference: Bates White Addendum Report, June 5, 2026, page 42, paragraphs 103 and 104.**

2 "Hydro concludes the preliminary results of its reactive power study highlight
3 that transmission and voltage constraints are key factors in evaluating
4 expansion alternatives and reinforce the importance of considering both
5 generation location, diversity, and system operability in long-term planning.

6 We agree, and while the reactive power study is not yet completed or provided
7 in Hydro's Evidentiary Update, preliminary results seem to provide support for
8 the Avalon CT's value in providing reactive power and voltage support for the
9 Island Interconnected System. Hydro should provide the Board with the
10 completed study as soon as practicable."

11 a) Provide a detailed explanation of how the Avalon CT could provide benefits in support
12 of the issues raised in relation to voltage stability and transmission line thermal
13 overloads during a bipole outage.

14 b) When will the Avalon Reactive Power Study be filed with the Board?
15
16

17 A. a) During a Labrador-Island Link ("LIL") bipole outage, power flow on the 230 kV transmission
18 system between Bay d'Espoir ("BDE") and Soldiers Pond ("SOP") increases due to the loss of
19 LIL imports directly into SOP. This situation presents two key challenges during high demand
20 periods.

21 **1. LIL Bipole Trip – Voltage Collapse in Sunnyside:** During peak load conditions,
22 Newfoundland and Labrador Hydro ("Hydro") operates generation on the Avalon
23 Peninsula for two reasons: (i) to meet system reserve requirements; and (ii) to avoid
24 voltage collapse in the event of a LIL bipole trip.

25 Hydro's Avalon Reactive Power Study – Phase 1 includes a review of the risk of
26 voltage collapse following the retirement of the Holyrood Thermal Generating
27 Station ("Holyrood TGS"). The study found that voltage collapse may occur in
28 Sunnyside immediately due to the sudden increase in power transfer from BDE–SOP
29 following a LIL bipole trip. The risk of this voltage collapse increases with the

1 retirement of Holyrood TGS, as BDE–SOP power flows are inherently higher without
2 Holyrood TGS in service.

3 The Avalon Reactive Power Study – Phase 1 demonstrates that for scenarios
4 involving the addition of BDE Unit 8 and the Avalon Combustion Turbine (“CT”),
5 normal dispatch of the Avalon CT to meet reserve requirements is sufficient to
6 ensure voltage stability. Further, Avalon CTs will also be equipped with synchronous
7 condenser capability, providing an additional means of mitigating voltage collapse
8 risk without the need to burn fuel, particularly at intermediate Island demand levels.
9 Scenarios involving increased off-Avalon generation are being assessed as part of
10 the Phase 2 study to evaluate the requirement of increased Avalon CT dispatch or
11 the addition of reactive power support at Sunnyside.

12 **2. LIL Shortfall Scenario – Risk of Transmission Thermal Overloads:** During an
13 extended LIL bipole outage (“LIL Shortfall Scenario”) at high load conditions, Avalon
14 demand is supplied by increased eastward power flow across the BDE–SOP
15 transmission system. In this operating state, a contingency involving the loss of a
16 230 kV line between BDE and SOP results in unacceptable thermal overloads and/or
17 low voltage levels. At present, Holyrood TGS operation naturally reduces BDE–SOP
18 flow as it is needed to meet demand and reliability requirements during high load
19 conditions. After the retirement of Holyrood TGS, there would not be enough
20 downstream generation to avoid thermal overload conditions following 230 kV line
21 trips. The Avalon CT would partially offset the loss of Holyrood TGS by reducing
22 loading on the 230 kV transmission system; however, it would not provide sufficient
23 relief to fully eliminate the thermal overloads. As a result, mitigation would require
24 either (i) upgrades to the 230 kV transmission system or (ii) a Remedial Action
25 Scheme (“RAS”) involving the instant reduction of BDE–SOP transfers through
26 downstream load shedding. These two approaches differ significantly in terms of
27 required capital investment. Under the current minimum-investment assumption,
28 transmission upgrades would include the addition of a third transmission line from
29 Western Avalon Terminal Station to SOP Terminal Station, with an estimated cost of
30 approximately \$216 million. Hydro is also investigating the application of Dynamic

1 Line Rating technology to select 230 kV lines between BDE and SOP. Should Island
2 demand exceed forecast levels, additional capital investment in the BDE–SOP
3 transmission system may be required.

4 Hydro is currently collaborating with Newfoundland Power Inc. on the design of the Avalon
5 RAS, the outcomes of which will inform the development of a cost estimate. However,
6 Hydro expects the cost of the Avalon RAS to be considerably less than the transmission
7 upgrades.

8 The need for transmission upgrades or the Avalon RAS is independent of the generation
9 expansion plan and is primarily driven by the retirement of Holyrood TGS. While additional
10 generation on the Avalon may provide partial mitigation, the underlying system constraints
11 persist unless approximately 400–500 MW of new generation is added on the Avalon
12 Peninsula. The Avalon CT would complement the Avalon RAS by reducing the magnitude of
13 customer impacts when the RAS is activated. As a result, the combined implementation of
14 these solutions is strongly recommended to address the LIL Shortfall Scenario.

- 15 **b)** The Avalon Reactive Power Study – Phase 1 has been completed and is currently undergoing
16 Hydro’s internal review process. Phase 1 focused on assessing transmission system impacts
17 associated with a generation expansion scenario limited to the Avalon CT and BDE Unit 8 (or
18 the minimum investment case). The study indicates that a generation expansion scenario
19 consisting solely of the Avalon CT and BDE Unit 8 can be accommodated without the need
20 for additional reactive power support on the BDE–SOP transmission system.

21 Hydro has determined that additional analysis is required beyond the scope of Phase 1 to
22 assess further off-Avalon generation expansion. Accordingly, Hydro will proceed with a
23 Phase 2 study that will focus on other potential off-Avalon generation expansion scenarios.

24 Hydro anticipates submitting the Phase 1 results by mid-July, with Phase 2 expected to be
25 completed by December 2026.