

1 Q. **Reference: Life Extension Application, Schedule 1, Attachment 1, Basis of Estimate, page 11 of**
2 **225.**

3 "Spare Parts:

- 4 • Brake shoes and seals
- 5 • Bearing pads and springs
- 6 • Set of seals
- 7 • Slings
- 8 • Miscellaneous tooling."

9 Explain why Hydro has not included a set of spare stator windings on the list of spare parts.

10

11

12 A. Newfoundland and Labrador Hydro has included the necessary spare parts for the stator within
13 the item titled "Replacement of stator windings." Ten percent extra bars are typically included in
14 the production run to be used as spares. Also included are the various winding materials,
15 including caps, lashings, brazing material, etc., required to install the spare stator bars. Similarly,
16 the re-insulation of the spare rotor pole is included in the item "Re-insulation of rotor poles."
17 The "Spare Parts" category only included spare parts that were not included elsewhere.