

1 Q. **Reference: Application, Capital Programs and Projects, Upgrade Distribution System (2026-**  
2 **2027) – Wiltondale**

3 It is stated (page 2) *“A Supervisory Control and Data Acquisition (“SCADA”) system will also be*  
4 *installed to allow for remote control and/or monitoring of the new assets from Hydro’s Energy*  
5 *Control Centre.”* Please elaborate. Will a completely new SCADA system be required?

6  
7  
8 A. No, a completely new Supervisory Control and Data Acquisition (“SCADA”) system is not  
9 required. A new Remote Terminal Unit (“RTU”) will be installed at Wiltondale Terminal Station,  
10 which will interface with Newfoundland and Labrador Hydro’s (“Hydro”) existing SCADA system.  
11 This new RTU is required for remote control and monitoring of the new assets at Wiltondale  
12 from Hydro’s Energy Control Center.