

Q. **2026 Capital Budget Application, Project 8, Widen Right of Way – Gros Morne National Park, page 1, lines 11-12 and page 2, line 1.**

“...ROWS of lines that run through the Park are currently narrower than those of all other Newfoundland and Labrador Hydro TLs by approximately 40-50%.”

Please provide a table outlining:

- i. The current width of each identified Transmission Line Right of Way (“ROW”) that is planned to be widened during the project,
- ii. The planned width of these ROWs after the project is completed, and
- iii. The standard ROW width for transmission lines on Hydro’s transmission system outside of the Gros Morne National Park with equivalent voltages.

A. Please refer to Table 1 for the current width of each transmission line (“TL”) right-of-way (“ROW”) that is planned to be widened during the project, and the planned width of these ROWs after the project is complete. The standard ROW width for 69 kV transmission lines on Newfoundland and Labrador Hydro’s transmission system outside of Gros Morne National Park is 15 meters.

Table 1: Proposed TL ROW to be Widened

Line	Voltage (kV)	Current ROW Width (meters)	Planned Widened ROW Width (meters)
TL226	69	9	11-16
TL227	69	9	11-16
TL229	69	9	11-16