

1 Q. **Reference: Project 2: L23/24 Steel-Tower Transmission Line Renewal (2026 - 2029)**

2 Page 1, lines 7-9.

3 "In 2024, Stantec completed another, more extensive assessment to review additional
4 deficiencies identified during the 2023 inspection."

5 In 2024, did Stantec inspect the condition of the conductor? If yes, what was the condition of
6 the conductor? If not, why not?

7

8

9 A Yes, the inspection completed by Stantec included all aspects of the transmission lines, including
10 steel members, hardware, and the conductor. The conductor was analyzed and observed to be
11 in good condition, with no visible signs of deterioration or mechanical damage.