1	Q.	Refe	Reference: Project 5: Replace Heavy-Duty Mobile Equipment (2026 - 2028)	
2		Page	e 8, lines 27-29.	
3		a)	Has Hydro explored opportunities to rent tracked units with aerial devices from	
4			Newfoundland and Labrador companies that contract to undertake transmission line	
5			maintenance and construction? If not, why not?	
6		b)	Provide a cost benefit analysis for the rental of mobile equipment compared to	
7			owning this mobile equipment.	
8				
9				
LO	A.	a)	Newfoundland and Labrador Hydro ("Hydro") does not consider renting tracked units	
l1			with aerial devices as a viable alternative to its project to Replace Heavy-Duty Mobile	
L2			Equipment. Any rental units that may be available would have to meet Hydro's	
L3			specifications which can include modifications, have a suitable preventive maintenance	
L4			program, and be readily available when needed. The readiness and availability of key	
L 5			aerial track units during unplanned system events and during times of severe weather	
L6			are critical to maintaining the provision of safe and reliable electricity to customers.	
L7			Stand by and mobilization and demobilization costs for contract equipment are	
L8			substantial, and the majority of this equipment operates in rural areas where rental	
L9			opportunities are limited.	
20		b)	Hydro has not conducted a cost benefit analysis as rental is not considered a viable	
21			alternative.	