

1 Q. **Reference: Project 9: Overhaul Major Pumps (2026) Page 4, line 2.**

2 "The Unit 1 East CW Pump is one of two identical vertical pumps (Figure 2) inside Pumphouse
3 1."

4 Will Board Order No. P.U. 29(2025) approving a Level 2 Condition Assessment for only
5 Pumphouse 2 impact Hydro's ability to complete the Pumphouse 1 scope of work for 2026?

6

7

8 A. Newfoundland and Labrador Hydro ("Hydro") does not expect that the decision to only
9 complete a Level 2 Condition Assessment on Pumphouse 2 in 2025 will impact the overhaul of
10 the Unit 1 East cooling water ("CW") pump in 2026. Hydro has developed an engineered
11 execution/lift plan specifically for the removal of the CW pumps for overhauls that considers the
12 load restrictions currently in place for the pumphouse floors, should concerns remain regarding
13 the condition of the sump.