

1 Q. **Reference: Volume II, Exhibit 4, Section 2.1.1, Table 1, and Volume 1, Schedule F 1.3.2, Page 1**
2 **of 3 and PUB-NLH-101, Issue Topic: Cost of Service Methodology.**

3 Please provide a reconciliation of the Hydro Rural Interconnected electricity requirements for
4 2027 Test Year between (i) the 462 GWh shown in Volume II, Exhibit 4, Section 2.1.1, Table 1
5 and (ii) the 426 GWh shown in Volume 1, Schedule F 1.3.2, Page 1 of 3.

6
7
8 A. The Hydro Rural Interconnected electricity requirement of 462 GWh presented in Volume II,
9 Exhibit 4, Section 2.1.1, Table 1 of Newfoundland and Labrador Hydro's 2026 General Rate
10 Application is measured before distribution losses. The 426 GWh amount shown in Volume I,
11 Schedule F 1.3.2, page 1 of 3, is measured after distribution losses. Accordingly, the difference of
12 36 GWh represents distribution losses within the Hydro Rural Interconnected system.