

1 Q. **Reference: Response to PUB-NLH-117**

2 How many customers are served by the remotely monitored and controlled reclosers at Upper
3 Salmon Generation Station, Hampden Terminal Station and Jackson's Arm Terminal Station?

4

5

6 A. The customer count associated with each site listed is as follows:

- 7 • Upper Salmon Hydroelectric Generating Station: one customer (Hydraulic Generation),¹
8 multiple services for a single customer;
- 9 • Hampden Terminal Station: 285 residential customers; and
- 10 • Jackson's Arm Terminal Station: 478 residential customers.

¹ This recloser only serves equipment at the plant level. There are no residential customers.