

1 Q. Provide the computation of the upstream capacity being charged to Carol Automobile Ltd.

2

3

4 A. The upstream capacity charge calculation for Carol Automobile Ltd. is as follows:

Applicant's Peak Demand Request	A	
(16 kW approved in 2021 plus 240 kW requested in 2025; totaling 256 kW):		256 kW
Basic Capacity Investment	B	200 kW
Expansion Cost	C	465 \$/kW
Basic Capacity Investment Credit	$D = B \times C$	\$93,000
Upstream Capacity Cost	$E = A \times C$	\$119,040
Upstream Capacity Charge	$F = E - D$	\$26,040