

- 1 **Q. Please provide a list of all poles replaced on these transmission lines over the last ten**  
2 **(10) years together.**  
3
- 4 A. Over the past 10 years, Newfoundland Power has replaced a total of 12 poles on  
5 transmission lines 363L, 403L and 49L as a result of deficiencies identified during annual  
6 inspections.

**Table 1**  
**Transmission Line**  
**Pole Replacements - 2009 to 2018**

Transmission Line	Number of Poles
363L	2
403L	4
49L	6