

- 1 **Q. (Reference Schedule B, LED Street Lighting Replacement) It is stated (page**
2 **2) "Street light fixtures will be replaced on an ongoing basis throughout the**
3 **year in response to street light trouble calls."**
4 **a) How many street light trouble calls did NP respond to in each year for the**
5 **period 2015 to 2024?**
6 **b) Does NP expect sufficient number of street light trouble calls to occur in**
7 **2026 to enable it to replace 9,400 HPS as planned? If not, will HPS fixtures be**
8 **replaced in the absence of any call even if the fixture and other equipment on**
9 **the pole is functioning normally?**
10 **c) Under what program does NP respond when it receives a street light**
11 **trouble call when there is already a LED fixture in place but repairs are**
12 **necessary?**
13
14 **A. a) Table 1 provides the number of street light trouble calls responded to in each year**
15 **from 2015 to 2024.**

Table 1 Street Light Trouble Call Response	
Year	Quantity of Street Light Trouble Calls Completed
2015	9263
2016	10702
2017	11770
2018	12870
2019	11972
2020	11793
2021	11340
2022	10603
2023	10866
2024	11287

- 16 b) Yes, Newfoundland Power expects sufficient trouble calls to occur in 2026 to replace
17 the approximate 9,400 HPS street light fixtures as planned.
18
19 c) The *Replacement Street Lighting Program* addresses trouble calls where repairs are
20 required when an LED street light fixture is already installed.