

1 **Q. Reference: "2026 Capital Budget Application," Newfoundland Power Inc.,**
2 **June 27, 2025, sch. B, Rebuild Distribution Lines, p. 18.**

3
4 **Please provide SAIDI and SAIFI statistics for each year from 2020 to 2024 for**
5 **each line planned under the 2026 program scope in comparison to the**
6 **company average and the Electricity Canada Region 2 average.**

7
8 **A.** See Table 1 and Table 2 on the following pages for the SAIFI and SAIDI values,
9 respectively, from 2020 to 2024 for each feeder scheduled for inspection in 2025. These
10 figures are provided in comparison with both the Newfoundland Power (the "Company")
11 average and the Electricity Canada ("EC") Region 2 average.

Table 1 SAIFI Values 2020-2024					
Feeder	2020	2021	2022	2023	2024
BCV-02	1.17	0.33	0.55	0.83	0.02
BFS-02	0.52	0.21	0.11	0.08	2.15
BIG-02	2.06	5.56	1.02	0.00	0.05
BOT-02	0.23	0.25	1.05	0.04	3.04
CAR-03	0.30	0.31	2.07	1.01	0.09
CAR-04	0.00	0.08	0.14	0.01	0.42
CLK-03	1.03	1.06	0.03	1.06	0.10
CLK-04	0.04	1.13	0.21	1.38	0.03
CLV-02	0.47	0.04	1.08	0.51	0.06
FER-01	1.04	3.10	2.25	2.79	0.32
GAL-05	1.91	1.18	0.04	0.07	0.02
GAN-04	0.02	0.10	0.00	1.07	0.00
GDL-05	0.07	1.01	1.08	0.24	1.09
GDL-06	0.00	0.19	1.66	0.01	0.02
GFS-01	1.18	0.05	0.19	0.11	0.00
GFS-03	0.99	0.01	0.00	0.04	0.05
GFS-04	2.00	0.00	0.00	0.00	0.00
GFS-05	1.06	0.04	0.12	0.04	0.08
GFS-10	1.00	1.20	2.29	0.20	2.14
GLV-02	5.16	4.66	11.59	3.17	3.79
GPD-01	1.00	3.96	1.03	0.02	1.02
HAR-02	0.04	1.23	0.51	1.04	1.54
HGR-02	0.21	0.04	1.05	2.32	0.05
HWD-02	1.18	2.81	4.24	0.37	0.89
ISL-01	3.21	2.02	1.17	4.93	0.03
KEN-04	0.04	0.13	2.05	0.31	0.02
LGL-01	3.11	0.00	3.17	1.07	1.13
LLK-02	4.01	0.04	0.28	0.01	2.30
MIL-02	2.44	1.18	5.90	0.73	0.44
NHR-01	0.03	0.11	0.04	0.11	1.26
NWB-01	0.25	3.09	0.06	0.32	3.30
PAS-02	2.06	2.89	2.22	6.04	1.05
PBD-01	0.41	0.11	3.76	0.48	3.47
PEP-02	0.34	1.23	0.22	0.33	0.02
PUL-05	2.83	0.15	0.00	0.06	0.06
SLA-09	0.01	1.09	0.49	0.02	0.09
SPO-01	2.09	1.35	0.26	1.00	5.97
SPO-02	0.29	2.53	1.28	2.61	3.26
VIR-07	2.70	0.04	0.02	1.07	1.31
VIR-08	0.51	0.19	1.07	0.03	1.34
WAL-07	1.10	0.31	0.08	1.01	0.00
WAV-02	1.45	0.05	0.91	3.58	0.00
Company Avg.	1.63	1.31	1.37	1.21	1.21
EC Region 2	1.69	1.58	1.74	1.84	1.53

Table 2 SAIDI Values 2020-2024					
Feeder	2020	2021	2022	2023	2024
BCV-02	2.06	0.22	0.82	1.14	0.03
BFS-02	0.54	0.19	0.20	0.12	2.93
BIG-02	0.41	6.04	0.10	0.01	0.09
BOT-02	0.37	0.48	0.25	0.17	2.91
CAR-03	0.29	0.98	9.94	1.90	0.21
CAR-04	0.00	0.06	0.16	0.03	1.02
CLK-03	2.79	0.97	0.20	3.20	0.12
CLK-04	0.05	1.69	1.09	2.63	0.08
CLV-02	0.50	0.06	2.32	2.09	0.07
FER-01	3.11	1.54	3.65	0.46	1.10
GAL-05	0.86	0.15	0.14	0.19	0.02
GAN-04	0.03	0.12	0.00	0.23	0.00
GDL-05	0.23	0.04	2.40	0.51	1.68
GDL-06	0.00	0.24	1.40	0.02	0.05
GFS-01	1.31	0.05	0.32	0.12	0.01
GFS-03	1.12	0.01	0.00	0.02	0.12
GFS-04	3.44	0.00	0.00	0.00	0.00
GFS-05	1.44	0.04	0.19	0.05	0.45
GFS-10	2.00	1.92	1.46	0.29	2.55
GLV-02	4.41	5.10	18.25	7.60	15.50
GPD-01	2.05	0.75	2.36	0.56	0.15
HAR-02	0.10	1.74	0.70	0.48	1.83
HGR-02	0.40	0.05	1.95	3.93	0.08
HWD-02	2.80	1.34	1.97	1.33	1.15
ISL-01	19.15	2.03	1.94	3.05	0.06
KEN-04	0.05	0.15	0.99	0.59	0.03
LGL-01	2.23	0.01	25.82	0.59	0.68
LLK-02	2.01	0.05	0.21	0.02	0.81
MIL-02	5.47	2.47	6.56	1.91	1.15
NHR-01	0.06	0.11	0.07	0.16	0.45
NWB-01	2.10	10.57	0.12	0.94	10.53
PAS-02	0.55	1.23	2.21	10.55	1.37
PBD-01	0.79	0.27	5.45	0.90	5.84
PEP-02	0.88	1.72	0.95	0.76	0.03
PUL-05	1.56	0.27	0.02	0.11	0.11
SLA-09	0.01	1.57	0.19	0.06	0.15
SPO-01	1.72	1.82	0.27	0.12	6.08
SPO-02	0.81	1.68	2.56	1.49	1.19
VIR-07	2.66	0.05	0.06	0.16	2.76
VIR-08	0.74	0.42	1.21	0.08	1.74
WAL-07	2.38	0.52	0.14	0.03	0.00
WAV-02	2.50	0.18	4.02	7.90	0.00
Company Avg.	1.96	1.64	2.05	1.73	1.75
EC Region 2	3.71	3.20	3.76	3.62	3.12

1 It should be noted that the *Rebuild Distribution Lines* program is a preventative maintenance
2 program based on inspection results. The feeders listed above are inspected as part of
3 Newfoundland Power's 7-year distribution inspection cycle, and deficiencies are identified and
4 repaired on a prioritized basis. The inclusion of a feeder on this list does not imply that work will
5 necessarily be completed on a feeder under this program, but merely that the feeder inspection
6 will be completed. This program is not intended to address historically poor reliability
7 performance on a feeder, but rather to identify and repair deficiencies prior to outages
8 occurring.