

Newfoundland Power Inc.

2027 Capital Budget Application
June 29, 2026, 9:30 am

Whenever. Wherever.
We'll be there.

NEWFOUNDLAND 
POWER
A FORTIS COMPANY

Outline

- **Background**
- **2027 Capital Budget**
- **2027 Capital Projects**




Capital Planning at Newfoundland Power

- Comprehensive process determines scope, necessity and timing of capital expenditures
- Based on sound engineering and objective data:
 - Customer connections
 - System growth
 - Asset condition
 - Economic factors
 - Industry standards
 - Operational requirements
- Alternatives assessed, including deferral, modification or advancement

Deferred/Modified/Advanced Expenditures	
Projects planned for 2027 but deferred to subsequent years	7
Projects advanced to 2027	1
Previously deferred projects proposed for 2027	1
Projects modified in 2027	2


Aging Electrical System

Distribution Wooden Support Structures




Expected Service Life: 54 Years

Substation Power Transformers



Expected Service Life: 30-50 Years

Transmission Overhead Conductor



Expected Service Life: 63 Years




2027 Capital Budget


2027 Capital Budget

Expenditure Type	2027 Budget (\$000s)
Single-Year > \$750,000	79,411
Single-Year < \$750,000	9,723
New Multi-Year	9,551
Subtotal	98,685
Previously Approved Multi-Year	50,664
Total	149,349

Newfoundland Power Capital Expenditures (2016-2027F)



2027 Capital Budget by Asset Class



Distribution Investments

- 2,342 forecasted customer connections
- Feeder Refurbishments
 - St. John's region – CAB-01 & GDL-02
 - Eastern region – ILC-02 & MIL-02
 - Western region – GBY-01
- Distribution Reliability Initiative
 - Refurbishment of GLV-02
- Load growth
 - Two feeders – BLK-02 & CHA-04
 - Increased residential load growth driven by subdivision development and increased customers

2027 Capital Budget by Category


49 Projects

- Defined schedule, scope and budget based on detailed engineering estimates


22 Programs

- High volume, repetitive and ongoing work. Budget based on historical averages.

2027 Capital Budget by Category



2027 Capital Budget by Investment Classification



Renewal Investments

- Primarily condition-based
- Corrective and preventive maintenance programs
- Proposed refurbishment projects
 - Four power transformer replacements
 - Three substation refurbishments
 - One hydro plant refurbishment

2027 Capital Budget by Materiality Threshold

Threshold	Quantity of Projects/Programs	Percentage of Total Expenditures
Less than \$1 million	27	11%
\$1 million to \$5 million	31	34%
Greater than \$5 million	13	55%
Total	71	100%

Examples of Projects over \$5 million

- Portable substation
- Blaketown Substation Refurbishment and Modernization




2027 Capital Projects

Substation Power Transformer Strategy



- Most critical substation asset
- Second year of strategy
- Aging fleet
- Persistently long delivery lead times
- Constrained emergency response resources

Substation Power Transformers Age Profile



2027 Substation Power Transformers (\$11.2M)

- Proposing replacement of 4 power transformers
 - Laurentian T1
 - Lookout Brook T1
 - Harmon T1
 - Ridge Road T3
- External deterioration identified through condition assessments
- Internal deterioration identified through oil analysis
- Coordination with planned refurbishments




Portable Substation (\$9.9M)

- Aging substation transformer fleet
- Critical for emergency response
- Deployment for capital projects and planned maintenance



Historical and Forecasted Portable Substation Fleet Usage (May - November)



* Indicates usage with addition of new portable substation.


Distribution Reliability Initiative (\$2.9M)

Glovertown

- Distribution feeder GLV-02
 - Constructed in the 1960s
 - One of the worst performing feeders
 - Deteriorated conductor and poles
 - Two sections totaling 17 kilometres to be refurbished

Distribution Interruption Statistics
5-Year Average to December 31, 2025

Feeder	Customer Minutes of Outage	SAIFI	SAIDI	CHIKM	CIKM
GLV-02	1,004,070	5.64	10.85	133	69
Corporate Average	89,226	1.23	1.74	49	35



Gander-Twillingate System Planning Study (\$4.2M)

Justification:

- Transmission-level undervoltage condition near Twillingate
- Age and condition of GAN-T2 and 108L

Three-year plan filed in 2025 CBA:


- New 138 kV Transmission Line 148L from LEW-BOY (approved)
- New 138/66 kV Transformer for BOY Substation (approved)
- Associated upgrades at LEW and BOY substations (approved)
- Retirement of JON Substation (2027)
- Modifications to Transmission Lines 142L and 114L (2027)



Gander-Twillingate System Planning Study (\$4.2M)



COB-02 Extension



114L/142L

Proposed 2027 Work:

- Distribution Feeder COB-02 Extension
 - Maintains supply to JON Substation customers
- Transmission Line 114L Replacement and 142L Relocation
 - Maintains lines in/out of GBY Substation
 - Elimination of 3-terminal 142L/114L tap

Rose Blanche Hydro Plant Refurbishment (\$1.7M)

- 5% of total hydroelectric production from Newfoundland Power
- Major Equipment Issues
 - Outdated and substandard governor
 - Deteriorated hydraulic power unit
 - Outdated and substandard protection and control system display
 - Undersized auxiliary power unit
- Economic lifecycle analysis demonstrates benefit to customers



Auxiliary Power Unit



Governor Hydraulic Power Unit



Governor Control System



Protection and Control System Display



**Whenever. Wherever.
We'll be there.**

NEWFOUNDLAND 
POWER
A FORTIS COMPANY