

1 Q. Further to CA-NLH-53, in the event that both the primary and back-up auxiliary
2 power supplies are interrupted, what is the specified ride-through time in seconds
3 before the converter station is tripped?

4

5

6 A. It is required that controls and protection do not trip for low-voltage conditions up
7 to one second in duration.