

- 1 **Q: Do Liberty’s analyses indicate that Hydro has adequate control over the IIS to**
2 **operate the system in a secure and reliable manner?**
3
4
- 5 A. Liberty interprets the question of “control” in the traditional sense of operational
6 control by system operators at control centre(s). Liberty found that Hydro has
7 adequate control over its generation and transmission facilities. Control over its
8 distribution facilities is not as robust, due mostly to the widely dispersed load
9 pockets of customers throughout the Island of Newfoundland.