

1 Q. In reference to Table 23 in Appendix A [page 43] of the Teshmont Report please
2 confirm that gas turbines [Holyrood, Stephenville, Hardwoods] are assumed to be in
3 standby mode after Holyrood TGS is retired? If not, please explain.

4

5

6 A. It is confirmed.