

1 Q. Reference: Public Utilities Board Muskrat Falls Review, *Manitoba Hydro*
2 *International: Report on Two Generation Expansion Alternatives for the Island*
3 *Interconnected Electrical System*, January 2012, page 11.

4 “Design Loading Criteria – Nalcor has selected a 1:50-year
5 reliability return period (basis for design loading criteria)
6 for the HVdc transmission line, which is inconsistent with
7 the recommended 1:500-year reliability return period
8 outlined in the International Standard CEI/IEC 60826:2003
9 with Canadian deviations in CSA Standard CAN/CSA-C22.3
10 No. 60826:06, for this class of transmission line without an
11 alternate supply.”

12 Please describe in detail how the design of the Labrador – Island HVdc Link and the
13 proposed 230kV transmission line from Bay d’Espoir to Western Avalon each
14 correspond to weather data for rime, glaze icing and wind derived from available
15 weather studies. The description should address all climatic zones each
16 transmission line traverses.

17

18

19 A. Please see Hydro's response to NP-NLH-004 and NP-NLH-005.