1 Q. Set out in a table the Island Interconnected system capacity used by Hydro for 2 planning purposes, showing both capacity owned and purchased by Hydro and by 3 others and the total system capacity available to supply customers on each of December 1, 2013, December 29, 2013, January 4, 2014 (after system events at 4 Sunnyside Terminal Station) and January 15, 2014 and the system peak load on 5 6 each day. 7 8 9 The information as requested is set out in the attached tables (PUB-NLH-001 A. 10 Attachment 1 and Attachment 2). As the total system capacity available to supply 11 customers varies throughout the day, total system capacity at time of daily peak 12 demand is given. In the case of January 4, 2014, information is given both before 13 and after system events at Sunnyside Terminal Station, as the daily peak occurred

prior to the Sunnyside event.

14

Available Island Interconnected Generating Capacity (MW)

	Used for Planning December 1, 2013 December 29, 2013			
	Purposes (at Peak)	at 1715 hours	at 1705 hours	
Hydraulic				
Bay d'Espoir	592	617	617	
Cat Arm	127	138	138	
Upper Salmon	84	88	88	
Hinds Lake	75	78	78	
Granite Canal	40	41	32	
Paradise River & Mini Hydros	9	9	9	
Total Hydraulic	927	971	962	
Holyrood				
Holyrood Unit 1 ³	170	-	160	
Holyrood Unit 2	170	145	140	
Holyrood Unit 3	150	145	50	
Total Holyrood	490	290	350	
Standby GTs and Diesels				
Hardwoods GT	50	_	-	
Stephenville GT	50	30	-	
St. Anthony & Hawkes Bay Diesels	15	14	14	
Total Standbys and Diesels	115	44	14	
Purchases				
Exploits River Plants	91	88	48	
Star Lake	18	18	18	
Rattle Brook	3	4	-	
Wind Generation	22	29	34	
Corner Brook P & P Co-gen	15	8	8	
Corner Brook P & P Interruptible			60	
Total Purchases	149	147	168	
Deer Lake Power ²	101	121	61	
Newfoundland Power	97	127	120	
Total Island Capacity	1,879	1,700	1,675	
Total NLH System Capacity				
(Including Purchases)	1,681	1,452	1,494	
		1,214	1,418	
NLH System Peak Load		at 1655 hours	at 1725 hours	
CBPP Interruptible actually taken ¹		0	20	
		1,387	1,597	
Island Peak Load		at 1715 hours	at 1705 hours	

⁽¹⁾ When CBPP Interruptible is used, to determine what the actual Island Peak Load would have been, the amount of Interruptible actually used should be added to the Island Peak Load.

⁽²⁾ When CBPP Interruptible is available, Deer Lake Power available capacity is reduced to 61 MW.

⁽³⁾ A unit at Holyrood was out-of-service on Dec 01, as it was not required in service due to system demands being lower.

Available Island Interconnected Generating Capacity (MW)

	January 4, 2014	January 4, 2014	January 15, 2014
	at 0905 hours	at 2355 hours	at 1715 hours
Hydraulic			
Bay d'Espoir ³	617	617	540
Cat Arm	138	138	138
Upper Salmon	88	88	88
Hinds Lake	78	78	78
Granite Canal	32	32	-
Paradise River & Mini Hydros	9		9
Total Hydraulic	962	953	853
Holyrood			
Holyrood Unit 1	165	-	165
Holyrood Unit 2	165	165	165
Holyrood Unit 3	50		150
Total Holyrood	380	165	480
Standby GTs and Diesels			
, Hardwoods GT	-	-	50
Stephenville GT	30	30	25
St. Anthony & Hawkes Bay Diesels	14	14	14
Total Standbys and Diesels	44	44	89
Purchases			
Exploits River Plants	38	38	70
Star Lake	18	18	18
Rattle Brook	-	-	4
Wind Generation	-	-	49
Corner Brook P & P Co-gen	2	-	7
Corner Brook P & P Interruptible	60	60	60
Total Purchases	118	116	208
Deer Lake Power ²	61	61	61
Newfoundland Power	128	128	124
Total Island Capacity	1,693	1,467	1,815
Total NLH System Capacity			
(Including Purchases)	1,504	1,278	1,630
	1,464*	1,122*	1,041
NLH System Peak Load	at 0905 hours	at 2325 hours	at 1720 hours
CBPP Interruptible actually taken ¹	60	60	0
	1,529*	1,233*	1,243
Island Peak Load	at 0810 hours	at 2355 hours	at 1715 hours

^{*}Peak occurred prior to the Sunnyside event, when Holyrood Unit 1 was online

⁽¹⁾ When CBPP Interruptible is used, to determine what the actual Island Peak Load would have been, the amount of Interruptible actually used should be added to the Island Peak Load.

⁽²⁾ When CBPP Interruptible is available, Deer Lake Power available capacity is reduced to 61 MW.

⁽³⁾ A unit at Bay d'Espoir was out-of-service on Jan 15, as it was not required in service due to system demands being lower.