1	Q.	Further to the response to PUB-NLH-003, provide details on the amount of the
2		capacity shortfall and the number of customers affected by the two events listed in
3		the response and the recent period of rotating outages from January 2-8, 2014.
4		
5		
6	A.	The following sections outline the system supply impacts and what is known at this
7		time regarding the customer impact resulting from the two events listed in the
8		response to PUB-NLH-003 and the recent period of rotating outages from January
9		2-8, 2014. It is difficult to determine the capacity shortfall for each event due to the
10		dynamics of the power system, the range of accuracy in short-term load forecasting
11		and the effect that conservation and customer curtailment may have had on any
12		potential shortfall. However, to help the reader gain a better understanding of the
13		available reserves during each of the events, supply and demand charts are
14		provided in PUB-NLH-052, Attachment 1 for each of the days.
15		
16		Generation Supply Issues - January 23, 2006
17		The events on January 23, 2006 were related to generation supply issues. There
18		was 307 MW of generation capacity unavailable to the system with details as per
19		the following table.

Table 1

Generation Supply Issues - January 23, 2006								
Plant	Unit Rating (MW)	Unavailable Capacity (MW)	Notes					
Holyrood Unit 2	170		Boiler tube failure (January 6, 2006)					
Upper Salmon Unit	84	84	Frazil Ice blockage at intake					
Hardwoods Gas Turbine ¹	54	24	Derated due to control system failures					
Stephenville Gas Turbine ¹	54	27	Derated due to fuel nozzle failure on one End					
Holyrood Gas Turbine	10	2	Derated due to oil leak and fire (unit ran with fire watch)					
Total	372	307						

Notes:

1. The rating of these units subsequent to 2006 were adjusted to 50MW.

1 2

3

There were three Island Industrial Customers impacted on this day, as per the

4 following:

Table 2

Generation Supply Issues - January 23, 2006								
	Load Curtailment							
Customer Impacted	(MW)	Duration						
Corner Brook Pulp and Paper Limited	20	one hour						
Abitibi Consolidated - Grand Falls	20	one hour						
North Atlantic Refining Limited	4	seven hours						
Total	44							

5 6

7

8

9

System Events - January 11, 2013

There were a series of events on January 11, each with differing severity in terms of system generation supply and customer impacts. Please refer to Hydro's response to PUB-NLH-045 for additional detail.

10

As a result of the TL-201 transmission line trip at 0742 hours, there was a significant overfrequency experienced on the system and the loss of multiple generating plants

11 12

13

Page 3 of 5

and transmission lines. The units at Holyrood were already out of service due to the Holyrood switchyard electrical faults that had occurred earlier in the morning. The following table summarizes the total amount of unavailable system generating capacity following the TL-201 trip.

Table 3

Generation Supply Issues - January 11, 2013 (as at 0743 hours)								
Plant	Unit Rating (MW)	Unavailable Capacity (MW)	Notes					
Stephenville Gas Turbine	50	50	Unit unavailable due to work to rewind alternator					
Holyrood Units 1-3	490	490	Units had tripped previously in the morning					
Star Lake	18	18	Unit had tripped previously in the morning					
Cat Arm Units 1 and 2	127	127	Units tripped due to high system frequency					
Upper Salmon Unit	84	84	Unit tripped due to high system frequency					
Granite Canal Unit	40	40	Unit tripped due to high system frequency					
Other Purchases	83	21	NUGS reduction due to system upset					
Total	892	830						

Hydro does not have the detail regarding the specific number of customers impacted by the events on January 11, 2013. However, a table of supply point interruption data was prepared and is attached as PUB-NLH-052, Attachment 2.

Period of Feeder Interruptions – January 2-8, 2014

In the period from January 2 to 8, 2014 there were five days during which feeder interruptions were reported¹. In addition, there was a significant system event initiated by the failure of transformer T1 at Sunnyside. Table 4 contains the detail regarding the unavailable capacity immediately prior to the onset of feeder interruptions on each day. Table 5 outlines the available capacity following the system event initiated at Sunnyside at 0905 hours on January 4.

_

¹ There were no feeder interruptions reported on January 4 and 7, 2014.

Table 4

Rotating Outages - January 2-8, 2014									
	Unit	Jan-2 Unavailable	Jan-3 Unavailable	Jan-5 Unavailable		Jan-8 Unavailable			
	Rating	Capacity	Capacity	Capacity	Capacity ¹	Capacity ²			
Plant	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)			
Hardwoods Gas Turbine	50	50	50	50	50	50			
Stephenville Gas Turbine	50	20	20	20	20	25			
Holyrood Unit 3	150	100	100	100	150	100			
Holyrood Unit 2	170	5	5	5	170	5			
Holyrood Unit 1	170	5	5	170	170	170			
Granite Canal Unit	40	8	8	-	-	-			
Exploits Generation	63	25	24	26	21	14			
Total	693	213	212	371	581	364			

Notes:

- 1. On January 6, HRD Unit 2 (165 MW) and HRD Unit 3 (50 MW) were brought online during the period of feeder interruptions. The additional generation, as it became re-established, helped to minimize the duration and impact.
- 2. On January 8, HRD Unit 1 (165 MW) was brought on-line during the period of feeder interruptions. The additional generation, as it became re-established, helped to minimize the duration and impact.

Table 5

Plant	Unit Rating (MW)	Unavailable Capacity (MW)	Notes
Hardwoods Gas Turbine	50		Unit unavailable due to fuel valve issue
Holyrood Units 1-3	490	490	Units tripped during the system disturbance ¹
Stephenville Gas Turbine	50	50	
St. Anthony and Hawkes Bay Diesels	15	15	Units tripped during system disturbance
Cat Arm Units 1 and 2	127	127	Units tripped during system disturbance
Upper Salmon Unit	84	84	Unit tripped during system disturbance
Hinds Lake Unit	75	75	Unit tripped during system disturbance
Granite Canal Unit	40	40	Unit tripped during system disturbance
Purchases	59	59	Units tripped during system disturbance
Total	990	990	

Notes:

- 1. Unit 3 derated to 50 MW prior to this event due to forced draft fan failure.
- 2. Unit previously derated to 30 MW prior to this event due to cooling issues.

Page 5 of 5

- 1 Hydro does not have the detail regarding the specific number of customers
- 2 impacted during these events; however the following table outlines the feeder
- 3 interruption impact as reported by NP and Hydro.

Table 6

	Feeder Rota	tion Times	Newfoundla	nd Power	Newfoundland Hydro		
				Average		Average	
			Feeder	Duration	Feeder	Duration	
	Start	End	Interruptions	(mins)	Interruptions	(mins)	
January 2, 2014	4:13 PM	10:46 PM	77	88	6	30	
January 3, 2014	6:57 AM	7:36 PM	141	44	25	30	
January 5, 2014	7:23 AM	8:29 PM	158	54	5	60	
January 6, 2014	5:17 AM	10:48 AM	39	47	n/a	n/a	
January 8, 2014	3:23 PM	5:42 PM	32	25	3	30	

5


6


7


4


The feeder interruptions on January 6 were carried out on the Avalon Peninsula, as


there were generation issues at Holyrood that limited the supply to the area.




















Events on January 11, 2013

Delivery Point Affected	Start Time	Finish Time	Duration of Interruptions (mins)	MW Load	MW-Mins
Deer Lake Power - TL225	1/11/2013 7:43	1/11/2013 11:52	249.00	0.00	0.00
Deer Lake - NP	1/11/2013 7:43	1/11/2013 11:43	240.00	12.67	3,040.80
Port Aux Basques	1/11/2013 7:43	1/11/2013 11:20	217.00	15.74	3,415.58
Doyles	1/11/2013 7:43	1/11/2013 11:20	217.00	3.94	854.98
Grandy Brook	1/11/2013 7:43	1/11/2013 12:07	264.00	3.70	976.80
Bottom Brook - 400L	1/11/2013 7:43	1/11/2013 12:07	171.00	0.00	0.00
Stephenville	1/11/2013 7:43	1/11/2013 10:34	171.00	34.37	5,877.27
Massey Drive Bus B3 (1)	1/11/2013 7:43	1/11/2013 8:01	18.00	65.26	1,174.68
Massey Drive Bus B3 (2)	1/11/2013 8:10	1/11/2013 9:45	95.00	34.62	3,288.90
Massey Drive Bus B3 (3)	1/11/2013 7:43	1/11/2013 9:45	122.00	30.64	3,738.08
Massey Drive Bus B4	1/11/2013 7:43	1/11/2013 11:58	255.00	35.46	9,042.30
Wiltondale (1)	1/11/2013 7:43	1/11/2013 9:19	96.00	0.11	10.23
Glenburine (1)	1/11/2013 7:43	1/11/2013 9:19	96.00	2.13	204.67
Rocky Harbour (1)	1/11/2013 7:43	1/11/2013 9:19	96.00	3.09	296.77
Wiltondale (2)	1/11/2013 9:40	1/11/2013 9:47	7.00	0.05	0.36
Glenburine (2)	1/11/2013 9:40	1/11/2013 9:47	7.00	1.03	7.20
Rocky Harbour (2)	1/11/2013 9:40	1/11/2013 9:47	7.00	1.49	10.43
South Brook	1/11/2013 7:43	1/11/2013 7:48	5.00	3.79	18.95
Duck Pond Mine	1/11/2013 7:43	1/11/2013 23:59	976.00	8.57	8,364.32
St. Anthony	1/11/2013 8:01	1/11/2013 8:32	31.00	7.31	226.61
Roddickton	1/11/2013 8:01	1/11/2013 8:30	29.00	1.66	48.14
Cobb's Pond	1/11/2013 7:43	1/11/2013 9:12	89.00	60.00	5,340.00
Farewell Head	1/11/2013 7:43	1/11/2013 9:12	89.00	3.00	267.00
Glenwood	1/11/2013 7:43	1/11/2013 9:12	89.00	3.00	267.00
Grand Falls	1/11/2013 7:43	1/11/2013 10:03	140.00	60.00	8,400.00
Sunnyside - 100L	1/11/2013 7:43	1/11/2013 9:03	80.00	10.25	820.00
Sunnyside - 109L	1/11/2013 7:43	1/11/2013 9:03	80.00	11.81	944.80
Holyrood - 39L	1/11/2013 6:42	1/11/2013 6:43	1.00	0.00	0.00
Hardwoods (1)	1/11/2013 7:43	1/11/2013 8:00	17.00	159.72	2,715.24
Hardwoods (2)	1/11/2013 8:51	1/11/2013 9:14	23.00	108.09	2,486.07
Oxen Pond (1)	1/11/2013 6:48	1/11/2013 7:11	23.00	171.00	3,933.00
Oxen Pond (2)	1/11/2013 7:43	1/11/2013 8:03	20.00	115.49	2,309.80
Oxen Pond (3)	1/11/2013 8:51	1/11/2013 9:31	40.00	110.88	4,435.20
		Totals	4,020.00	967.99	72,515.19