

1 Q. In in the data set of historic energy consumption that Newfoundland and Labrador
2 Hydro uses in its load forecasting process, does that energy consumption data
3 include added corrections for interruptibles, voltage reductions and unserved
4 energy?

5

6

7 A. In the data set of historic energy consumption that Hydro uses in its load
8 forecasting process, energy consumption data does not include added adjustments
9 for interruptibles, voltage reductions and unserved energy. See also Hydro's
10 response to PUB-NLH-115.