| 1 | Q. | Further to PUB-NLH-438 what would be the impact on the Island Interconnected |
|----|----|---|
| 2 | | System of the Labrador Island Link operating for extended periods with reduced dc |
| 3 | | voltage? |
| 4 | | |
| 5 | | |
| 6 | A. | The Labrador – Island HVdc Link will be capable of delivering approximately 650 |
| 7 | | MW at Soldiers Pond in bipole mode when operating under reduced dc voltage |
| 8 | | conditions. During reduced dc voltage operation, there will be a prorate share |
| 9 | | between the Island use and the Nova Scotia Block. Given a continuous reduced dc |
| 10 | | voltage rating of 650 MW, the pro rata split will be 123 MW for the Nova Scotia |
| 11 | | Block and 527 MW for the Island. |
| 12 | | |
| 13 | | Under the reduced dc voltage operation, capacity available to supply Island load |
| 14 | | would include approximately: |
| 15 | | • 1013 to 1043 MW of on Island hydro-electric (variation due to reservoir |
| 16 | | levels); |
| 17 | | 234.7 MW of NLH standby combustion turbines and diesel (including the |
| 18 | | new 120 MW Holyrood CT); |
| 19 | | 41.5 MW of Newfoundland Power standby combustion turbine and |
| 20 | | diesel; |
| 21 | | 527 MW of supply at Soldiers Pond on LIL; and |
| 22 | | Customer generation including: |
| 23 | | o 79.1 MW of Newfoundland Power hydro-electric (gross |
| 24 | | continuous rating), and |
| 25 | | o 81.1 MW of 60 Hz Deer Lake Power hydro-electric generation, |
| 26 | | for a total Island capacity of 1976.4 to 2006.4 MW. |

Island Interconnected System Supply Issues and Power Outages

Page 2 of 2

- 1 Under a continuous reduced dc voltage scenario, there is sufficient Island
- 2 generating capacity to supply the total Island load until the mid-2030's based upon
- 3 recent load forecasts.