

1 Q. Further to the response to PUB-NLH-244, explain the involvement, if any, of the  
2 HVdc cable manufacturer in the specification of and/or the supervision of the actual  
3 rock dumping.

4

5

6 A. The cable manufacturer has no role in the specification or supervision of rock  
7 protection. This interface was/is managed by the Lower Churchill Project (LCP).

8

9 The cable manufacturer specified the maximum impact energy the cable could  
10 withstand during protection operations, and LCP ensured this specification will be  
11 met during cable installation.