

1 Q. Reference: Gas Turbine Failure Analysis - Final Report, January 11, 2017, page 8.

2 Hydro states that “some of the [Hardwoods] recommendations provided will
3 require detailed review of historical data and a full engineering review of the
4 recommended changes to identify how these changes could be implemented into
5 the existing systems.” Which of the Alba Power recommendations fall into this
6 category and what is the timetable for addressing them?

7

8

9 A. The Alba Power recommendation which requires engineering review prior to
10 implementation, is the review of unit acceleration and deceleration curves. This
11 review is currently ongoing in consultation with Alba Power and, due to its
12 complexity, conclusions related to recommended changes may not be reached until
13 Q2, 2017.