

Requests for Information

- 1 **Q. Further to the response to PUB-NP-010, explain if and how actual winter peaks are**
2 **incorporated or reflected in future load forecasts.**
3
- 4 A. Newfoundland Power's *actual* winter peaks are not reflected in Newfoundland Power's
5 future load forecasts.
6
- 7 Please refer to the response to Request for Information PUB-NP-010 where it is indicated
8 that to forecast its actual winter peak in an annual forecast would essentially require
9 Newfoundland Power to reliably forecast actual weather conditions months in advance.¹
10
- 11 Newfoundland Power's *weather normalized* winter peaks are reflected in Newfoundland
12 Power's future load forecasts.
13
- 14 Please refer to the response to Request for Information PUB-NP-006 for more
15 information on how Newfoundland Power forecasts winter peak.²

¹ See the response to Request for Information PUB-NP-010, lines 28-31 and footnote 2.

² See the response to Request for Information PUB-NP-006, page 2, line 1 to page 4, line 7.