

1 Q. How long would the fuel storage planned for the 100 MW combustion turbine allow  
2 it to operate at nameplate rating without being replenished?

3

4

5 A. The specified fuel oil tankage supplied under the EPC contract will allow the CTG  
6 unit to operate at its Maximum Continuous Rating (MCR) of 123.5 MW for a total of  
7 approximately 60 continuous hours. The MCR rating is based on ambient air  
8 temperature of 15 C. Based on an average output of 100 MW, the unit can run  
9 continuous up to 80 hours.